



8431 Murphy Dr
Middleton, WI 53562 USA

Telephone: (608) 826-4400
www.intertek.com

Certificate of Compliance


In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.


Applicant Name & Address:	Flame Safe Wood Products, Inc., 2653 Warfield Avenue, Fort Worth, TX 76106
Product Evaluated:	100% Cotton Tent canvas with Flame Safe Fabric Safe
Product Description:	100% cotton tent canvas (duct) fire retardant treated with Flame Safe Fabric Safe sprayed on at 200 Square feet per gallon (coverage rate)
Ratings & Principle:	PASS
Brand Name:	N/A
Relevant Standards:	NFPA 701-2015, METHOD 2 Standard Methods of Fire Tests for Flame Propagation Of Textiles and Films for Flat Sheets (Section 13.1.3)
Verification Issuing Office:	Intertek Testing Services NA, Inc. 8431 Murphy Dr Middleton, WI 53562
Date of Tests:	
Test Report Number(s):	

This verification is part of the full test report(s) and should be read in conjunction with them. This report does not imply product certification.

Completed by: Joel Zumwalt
Title: Lab Technician III
Intertek Building Products

Reviewed by: Sandy Osborne
Title: Lab Technician I
Intertek Building Products

Signature: 
Date: October 10, 2017

Signature: 
Date: October 10, 2017

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.