



Certificate of Compliance

You have been awarded:



Intertek Warnock Hersey Mark for fire resistant coatings

ASTM E2768: ASTM E84 (2013a)

Certificate number: WHI15 – 27317401

Organization:
Fire Prevention Technologies dba Flame Safe Chemical Corporation
2653 Warfield Ave
Fort Worth, TX 76106
United States of America

Product: Flame Safe Chemical Corporation – Fire Poly FP 75i
Flame Spread Index: 5
Smoke Developed Index: 60
Max Flame Front: 10.7 ft

Certification body: Intertek Testing Services NA, Inc.
Initial registration: April 28th, 2015
Date of expiry: April 28th, 2020
Issue status: 1

Dustin Behling		04/28/2015
Certification Coordination Manager		
Name	Signature	Date

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd., Arlington Heights, IL 60005 USA

www.intertek.com